

# Operating Instructions

## SFU

## Gas Sampling Unit



**Described product**

SFU (gas sampling unit)

Variants:

- Filter Unit SFU-BF NI
- Filter Unit SFU-3V NI
- Filter Unit SFU-BF NI GL

**Manufacturer**

Endress+Hauser SICK GmbH+Co. KG  
Bergener Ring 27  
01458 Ottendorf-Okrilla  
Germany

**Legal information**

This work is protected by copyright. Any rights derived from the copyright shall be reserved for Endress+Hauser SICK GmbH+Co. KG. Reproduction of this document or parts of this document is only permissible within the limits of the legal determination of Copyright Law. Any modification, abridgment or translation of this document is prohibited without the express written permission of Endress+Hauser SICK GmbH+Co. KG.

The trademarks stated in this document are the property of their respective owner.

© Endress+Hauser SICK GmbH+Co. KG. All rights reserved.

**Original document**

This document is an original document of Endress+Hauser SICK GmbH+Co. KG.



## Contents

|          |                                                                |           |
|----------|----------------------------------------------------------------|-----------|
| <b>1</b> | <b>About this document.....</b>                                | <b>5</b>  |
| 1.1      | Function of this document.....                                 | 5         |
| 1.2      | Target group.....                                              | 5         |
| 1.3      | Symbols and document conventions.....                          | 5         |
| 1.3.1    | Warning symbols.....                                           | 5         |
| 1.3.2    | Warning levels / signal words.....                             | 6         |
| 1.3.3    | Information symbols.....                                       | 6         |
| <b>2</b> | <b>Safety information.....</b>                                 | <b>7</b>  |
| 2.1      | Basic safety information.....                                  | 7         |
| 2.2      | Warnings on the device.....                                    | 7         |
| 2.3      | Intended use.....                                              | 8         |
| 2.4      | Qualification of the operator.....                             | 8         |
| <b>3</b> | <b>Product description.....</b>                                | <b>9</b>  |
| 3.1      | Product identification.....                                    | 9         |
| 3.2      | Product description.....                                       | 10        |
| 3.3      | Design.....                                                    | 11        |
| 3.3.1    | Gas sampling tube.....                                         | 11        |
| <b>4</b> | <b>Installation and start-up.....</b>                          | <b>13</b> |
| 4.1      | Important information.....                                     | 13        |
| 4.2      | Weatherproof cover.....                                        | 14        |
| 4.3      | Preparing the connection bundle.....                           | 15        |
| 4.4      | Mounting.....                                                  | 15        |
| 4.4.1    | Installing the welding neck flange.....                        | 15        |
| 4.4.2    | Connection of sample gas line.....                             | 17        |
| 4.4.3    | Connection of the pneumatic lines.....                         | 18        |
| 4.5      | Electrical installation.....                                   | 20        |
| 4.6      | Installing the gas sampling tube on the gas sampling unit..... | 22        |
| 4.7      | Installing the SFU on the welding neck flange.....             | 23        |
| <b>5</b> | <b>Maintenance.....</b>                                        | <b>24</b> |
| 5.1      | Important Information.....                                     | 24        |
| 5.2      | Maintenance plan.....                                          | 24        |
| 5.3      | Spare parts.....                                               | 25        |
| 5.4      | Replacing the sintered metal filter element.....               | 25        |
| 5.5      | Replacing the glass fiber filter element.....                  | 28        |
| 5.6      | Retrofitting the filter element.....                           | 31        |
| 5.7      | Checking for correct operation.....                            | 34        |
| <b>6</b> | <b>Troubleshooting.....</b>                                    | <b>35</b> |
| 6.1      | Troubleshooting.....                                           | 35        |
| <b>7</b> | <b>Disposal.....</b>                                           | <b>36</b> |
| <b>8</b> | <b>Technical data.....</b>                                     | <b>37</b> |
| 8.1      | Compliances and Standards.....                                 | 37        |

|     |                     |    |
|-----|---------------------|----|
| 8.2 | Dimensions.....     | 37 |
| 8.3 | Operating data..... | 38 |

# 1 About this document

## 1.1 Function of this document

These Operating Instructions describe:

- Device components
- Installation
- Operation
- Maintenance work required for reliable operation

## 1.2 Target group

This document is addressed to technicians (persons with technical understanding) installing, operating and maintaining the measuring system.

### Responsibility of the operator

- Use the device only as described in these Operating Instructions. The manufacturer assumes no responsibility for any other use.
- Maintenance work should be performed as prescribed in this Manual.
- Do not remove, add or change any components in or on the device unless such changes are officially allowed and specified by the manufacturer.
  - Otherwise the manufacturer's warranty becomes void.
  - Otherwise the device can become dangerous.
- Observe special local conditions.
  - Follow all local laws, regulations, and company policies applicable at the installation location.
- Retain documents. These Operating Instructions:
  - Must be kept available for reference.
  - Must be passed on to new owners.

### Requirements on the maintenance personnel

- The technician must be familiar with the exhaust gas technology of the operator's plant (overpressure, toxic and hot flue gases) and be able to avoid hazards when working on gas ducts.
- The technician must be familiar with handling compressed gas cylinders (span gases).
- The technician must be able to avoid hazards caused by noxious span gases.
- The technician must be familiar with gas lines (PTFE lines) and their screw fittings (be able to ensure gas-tight connections).
- Only electricians are permitted to work on the electrical system or electrical subassemblies.

## 1.3 Symbols and document conventions

### 1.3.1 Warning symbols

| Symbol                                                                              | Significance                  |
|-------------------------------------------------------------------------------------|-------------------------------|
|  | Hazard (general)              |
|  | Hazard by voltage             |
|  | Hazard by acidic substances   |
|  | Hazards by noxious substances |

| Symbol                                                                            | Significance                                   |
|-----------------------------------------------------------------------------------|------------------------------------------------|
|  | Hazard by high temperature                     |
|  | Hazard for the environment/nature/organic life |

### 1.3.2 Warning levels / signal words

#### **DANGER**

Risk or hazardous situation which will result in severe personal injury or death.

#### **WARNING**

Risk or hazardous situation which could result in severe personal injury or death.

#### **CAUTION**

Hazard or unsafe practice which could result in less severe or minor injuries.

#### **Notice**

Hazard which could result in property damage.

#### **Note**

Hints.

### 1.3.3 Information symbols

| Symbol                                                                              | Significance                                              |
|-------------------------------------------------------------------------------------|-----------------------------------------------------------|
|  | Important technical information for this product          |
|  | Important information on electric or electronic functions |

## 2 Safety information

### 2.1 Basic safety information


**WARNING**

Health risk through dangerous sample gas  
If dangerous sample gas is applied to the SFU:

- ▶ The operator is responsible for safe handling of sample gas.


**WARNING**

Risk of explosion in potentially explosive atmospheres

- ▶ Do not operate the SFU in potentially explosive atmospheres.


**WARNING**

Hazard through explosive or ignitable gases

- ▶ Do not use the SFU for measuring explosive or combustible gases.

### 2.2 Warnings on the device




Figure 1: Location of the warning signs on the device

- ① Warning sign "Hot surface!"
- ② Warning sign "Caution!"
- ③ Warning sign "Hot surface!"

Further warning signs can be found on the weatherproof cover: "Voltage!" and "Hot surface!".


**DANGER**

Hazard by voltage

- ▶ Only authorized electricians may perform work on electrical components.
- ▶ Do not touch live components.
- ▶ Disconnect the device from the power supply before working on electrical components (e.g. by switching off the measuring system).

**WARNING**

Risk of burns on hot surfaces

- ▶ Avoid contact with hot surfaces or wear protective clothing (e.g. protective gloves).
- ▶ Lay hot parts on fireproof supports only.

## 2.3 Intended use

The gas sampling unit is used for extracting a partial stream of a gas mixture (usually flue gas) from a line, stack or similar and for retaining particles that are contained in the gas stream.

## 2.4 Qualification of the operator

The SFU may only be maintained by persons properly instructed on the tasks assigned, possible risks and protective measures.

### 3 Product description

#### 3.1 Product identification

|              |                                                                                                                                                                                                                         |
|--------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Product name | SFU<br>Variants:<br><ul style="list-style-type: none"> <li>■ Filter Unit SFU-BF NI</li> <li>■ Filter Unit SFU-3V NI</li> <li>■ Filter Unit SFU-BF NI GL</li> </ul> The type designation can be found on the type plate. |
| Manufacturer | Endress+Hauser SICK GmbH+Co. KG<br>Bergener Ring 27 · 01458 Ottendorf-Okrilla · Germany                                                                                                                                 |
| Type plate   | The type plate is located on the underside of the gas sampling unit.                                                                                                                                                    |

##### Type plates and variants

|                                                                                                               |                  |
|---------------------------------------------------------------------------------------------------------------|------------------|
| <b>Filter Unit SFU-BF NI</b>                                                                                  | <b>115/230 V</b> |
| PN 2041536                                                                                                    | 50-60 Hz         |
| SN xxxxxxxx                                                                                                   | 450 VA           |
| Gas sampling unit for typical use with measuring systems MCS100E HW, MCS300P HW, MCS100 FT                    |                  |
| <ul style="list-style-type: none"> <li>• Filter 2 µm stainless steel</li> <li>• Backflush possible</li> </ul> |                  |

|                                                                                 |                  |
|---------------------------------------------------------------------------------|------------------|
| <b>Filter Unit SFU-3V NI</b>                                                    | <b>115/230 V</b> |
| PN 2056986                                                                      | 50-60 Hz         |
| SN xxxxxxxx                                                                     | 450 VA           |
| Gas sampling unit for typical use with measuring system MERCEM300Z              |                  |
| <ul style="list-style-type: none"> <li>• Filter 2 µm stainless steel</li> </ul> |                  |

|                                                                                                                                                                                              |                  |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|
| <b>Filter Unit SFU-BF NI GL</b>                                                                                                                                                              | <b>115/230 V</b> |
| PN 2058208                                                                                                                                                                                   | 50-60 Hz         |
| SN xxxxxxxx                                                                                                                                                                                  | 450 VA           |
| Gas sampling unit for typical use with measuring system MARSIC300                                                                                                                            |                  |
| <ul style="list-style-type: none"> <li>• Filter 0.1µm glass fiber</li> <li>• Backflush possible</li> <li>• Mechanically reinforced for higher vibrations (maritime certification)</li> </ul> |                  |



##### NOTICE

It is possible that your SFU has a different configuration to that described in this Manual.

- Refer to the System Documentation delivered with your SFU for the individual configuration of your system.

## 3.2 Product description




Figure 2: Configuration example of a SFU

- ① Filter housing
- ② Gas sampling tube (unheated)
- ③ Weather hood
- ④ Pre-filter (optional)

The gas sampling unit consists of filter housing, gas sampling tube, weatherproof enclosure and optional pre-filter.

### Application area

The gas sampling unit SFU is used for flue gas extraction and filtering for analysis in a measuring system.

The flue gas is taken via a gas sampling tube and fed to a measuring system after filtration.

As an option, the gas sampling tube can be heated.

As an option, the gas sampling tube contains a pre-filter at the probe tip.

### Measuring system

The gas sampling unit is operated on an Endress+Hauser measuring system. Thus, only this operating mode is described in this Manual.

Applications with customer-owned peripheral devices are not planned.

### 3.3 Design




Figure 3: SFU-BF NI and SFU-BF NI GL

- ① Gas sampling tube
- ② Filter housing
- ③ 3 pneumatic lines (backflush, activation of main valve, zero gas)
- ④ Output sample gas line
- ⑤ Input connection bundle (electrical and pneumatic lines)
- ⑥ Filter element with rotary handle




Figure 4: SFU-3V NI

- ① Gas sampling tube
- ② Filter housing
- ③ 3 pneumatic lines for activation
- ④ Output sample gas line
- ⑤ Input connection bundle (electrical and pneumatic lines)
- ⑥ Filter element with rotary handle
- ⑦ Manual activation of calibration gas
- ⑧ Automatic activation of calibration gas

The gas sampling unit consists of the following subassemblies:

- Gas sampling tube:
  - Heated gas sampling tube:
  - Unheated gas sampling tube
  - Optional: Pre-filter at the tip of the gas sampling tube
- SFU consisting of:
  - Heated filter housing with filter element
  - Weatherproof cover

The electrically heated filter housing is made of coated aluminum. The filter housing is insulated by an aluminum housing lined with polyimide.

The weatherproof cover consists of powder coated steel plate.

#### Thermostatic control

The gas sampling unit is thermostatically controlled.

- Heating control with Pt100 sensor and external heating control
- Limit value monitoring in the controller of the measuring system

#### 3.3.1 Gas sampling tube

The length of the gas sampling tube depends on the conditions at the sampling point.

The gas sampling tube is available as heated and unheated version.

The gas sampling tube can be equipped with a pre-filter (2µm or 10µm). The pre-filter is screwed to the probe tip.

Type and length of the gas sampling tube are described in the supplied system documentation.

**NOTE**

The heated gas sampling tube is supplied pre-assembled.

Further assembly steps are necessary for the unheated gas sampling tube [see "Installing the gas sampling tube on the gas sampling unit", page 22](#).




Figure 5: Unheated gas sampling tube




Figure 6: Heated gas sampling tube:



Figure 7: Pre-filter

## 4 Installation and start-up

### 4.1 Important information


**WARNING**

Risk of injury by a heavy load

The device weighs approx. 20 kg.

- ▶ Use proper lifting techniques to lift or move the device.
- ▶ Do not lift the device by holding it at the weatherproof cover. Always hold it at the device base.
- ▶ If necessary, work in pairs.


**WARNING**

Health risk through dangerous sample gas

If dangerous sample gas is applied to the SFU: The operator is responsible for safe handling of sample gas.

- ▶ In addition to these Operating Instructions, observe all local laws, technical rules, and company-internal instructions valid at the site where the SFU is installed.
- ▶ Operate the SFU only in rooms with adequate installation OR install suitable gas monitoring equipment.
- ▶ Channel sample gas off safely.


**WARNING**

Hazard through sample gas pressure

The stacks can have underpressure or overpressure.

- ▶ Observe information from the plant operator.


**WARNING**

Risk of burns on hot surfaces

Filter housing, flanges and sample gas line can be hot.

- ▶ Allow the surface of the device parts to cool down to body temperature or wear suitable protective gloves.


**WARNING**

Danger to life by electric voltage

- ▶ Only allow an authorized electrician to work on the electric system.

The assembly of the gas sampling unit contains the following work steps:

| Step | Work step                                 | Special features                               | Side                    |
|------|-------------------------------------------|------------------------------------------------|-------------------------|
| 1    | Install the welding neck flange           | Has to be performed by the operator beforehand | <a href="#">page 15</a> |
| 2    | Connect the sample gas line               |                                                | <a href="#">page 17</a> |
| 3    | Connect the hoses for valves              |                                                | <a href="#">page 18</a> |
| 4    | Connect the electrical connections        |                                                | <a href="#">page 20</a> |
| 5    | Install the gas sampling tube             | Only necessary for unheated gas sampling tubes | <a href="#">page 22</a> |
| 6    | Attach the SFU to the welding neck flange | Observe preheating period                      | <a href="#">page 23</a> |

## 4.2 Weatherproof cover




Figure 8: Weatherproof cover SFU-BF NI and SFU-3V NI

- ① Screw closure
- ② Pilot pin and guide slot (covered)




Figure 9: Weatherproof cover SFU-BF NI and SFU-BF NI GL

- ① Screw closure



### DANGER

Hazard by voltage

Live parts are accessible after the weatherproof cover has been opened.

- Disconnect the gas sampling probe from the power supply before opening the cover (for example by switching off the measuring system).



### CAUTION

Risk of burns on hot surfaces

You can perform the work while the filter is hot.

- Wear suitable gloves.

### Removing the weatherproof cover

- 1 Unlock the screw closures.
- 2 Pull the weatherproof cover away from the gas sampling tube and lift.

### Fitting the weatherproof cover

- 1 Fit the weatherproof cover in the direction of the gas sampling tube.
- 2 Lock the screw closures.

### 4.3 Preparing the connection bundle



Figure 10: Standard connection bundle

Standard hose bundle cable (system-specific example) with:

- Power supply
- Grounding conductor yellow/green
- Signal lines
- Tube, gray: Zero gas/span gas
- Tube, black: Main valve
- Tube, blue: Backflush

The connection bundle (option) connects the SFU with the measuring system.

#### Preparation of the connection bundle



#### NOTE

Leave a sufficient length for pulling the gas sampling unit out of the stack (approx. 2 m).

- 1 Strip the connection bundle and shorten the hoses and lines to the required length. Cut the hoses at right angles. Avoid damaging the lines and hose lines.
- 2 Cut the flexible wires to the required length. Press the crimp lead end sleeves onto the ends of the flexible wires.

### 4.4 Mounting

#### 4.4.1 Installing the welding neck flange



#### WARNING

Risk of burns by hot flanges.

The flanges can reach high temperatures.

- Before starting any work on the flanges, allow the flanges to cool down to body temperature or wear appropriate protective gloves.



#### DANGER

#### Health risk through hot or toxic gases/dusts in the measuring duct

The measuring duct can contain hot or toxic gases or dust deposits which can escape when opening the duct-side flange. Even if the measuring duct is out of operation during the installation, escaping gases can lead to severe damage to health.

- Always put the measuring duct out of operation for the duration of the installation.
- If required, purge the measuring duct with ambient air before starting installation work.
- During installation work, always wear protective clothing which is suitable or specified by the operating company.

The operator is responsible for installing the welding neck flange.

The specifications of the flange connection are described in the System Documentation delivered.




Figure 11: Installation requirements for welding neck flange

- ① Gas sampling tube
- ② Stack wall
- ③ Welding neck flange
- ④ Probe filter

- Attach the flange with a tilt of approx. 10°.
- The minimum distance a behind welding neck flange must be min. the length specified in the following table in order to maintain and dismantle the gas sampling unit.

Table 1: Minimum distance behind welding neck flange

| Length of gas sampling tube | Minimum distance a |
|-----------------------------|--------------------|
| 0.5 m                       | 915 mm             |
| 0.8 m                       | 1215 mm            |
| 1.0 m                       | 1415 mm            |
| 1.5 m                       | 1915 mm            |
| 2.0 m                       | 2415 mm            |

#### 4.4.2 Connection of sample gas line




Figure 12: Sample gas connection SFU-BF NI and SFU-BF NI GL

- ① Insulating shell
- ② Clamping ring screw connection
- ③ Sample gas line
- ④ Hose clamp
- ⑤ Screw for hose clamp
- ⑥ Opening for screwdriver




Figure 13: Sample gas connection SFU-3V NI

- ① Clamping ring screw connection
- ② Insulating shell
- ③ Sample gas line
- ④ Hose clamp
- ⑤ Screw for hose clamp
- ⑥ Opening for screwdriver



#### NOTE

If you lay the heated sample gas line before installing the gas sampling unit: Observe the installation of the sample gas line:

- ▶ Start laying at the measuring system:
  - The end **with** electrical connection is connected to the measuring system.
  - The end **without** electrical connection is connected to the gas sampling unit. Roll up excess length at the gas sampling unit. Leave enough length for pulling out the gas sampling unit (approx. 2 m).
- ▶ Protect the line from damage (chafing through vibration, mechanical and thermal load).
- ▶ Observe a minimum bending radius of 300 mm.

1. Remove the weatherproof cover (see "Weatherproof cover", page 14).
2. Unscrew the large cap nut and slide it onto the sample gas line.
3. Unscrew the insulation half-shell.
4. Lead the sample gas line through the bottom of the installation plate and the hose clamp.
5. Screw the sample gas line tight on the clamping ring screw connection.
  - For SFU-3V NI: The tube connections are color coded. Do not mix up the connections.
  - For first screwing (clamping ring still loose): 1¼ turn to "hand-tight".
  - For further screwing: (clamping ring tight) ¼ turn to "hand-tight".
6. Fasten the sample gas line using a hose clamp. The screw head can be reached via an opening in the chamfer of the installation plate.
7. Screw the insulation half-shell back on again.
8. Tighten the cap nut hand-tight.
9. Check hose connections for leaks:
 

The leak tightness check is performed via the connected measuring system: See the Operating Instructions of the measuring system.

#### 4.4.3 Connection of the pneumatic lines

**NOTICE**

Risk of damaging the measuring system.

- Ensure correct assignment of the pneumatic connections.
- Ensure leak tightness of the system.


**Connection for SFU-BF NI and SFU-BF NI GL**

Figure 14: Connection of pneumatic lines SFU-BF NI and SFU-BF NI GL

- ① Backflush
- ② Main valve
- ③ Zero gas
- ④ Installation plate

1. Push the cap nut onto the connection bundle.
2. Lead the connection bundle through the installation plate and the cable gland.
3. Connect the 3 hoses with the 3 hose fittings on the filter housing and ensure correct layout.
4. Push the hoses flush over the hose connections of the hose fitting.
5. Hose for the zero gas: Use clamping ring screw connection with support sleeve.
6. Tighten the cap nut by hand.
7. Screw the cable gland tight.

### Connection for SFU-3V NI




Figure 15: Connection of pneumatic lines  
SFU-3V NI

- ① Tecalan tube #1 to V2
- ② Tecalan tube #2 to V3
- ③ PTFE tube 6 mm (NpT1/4") to V1
- ④ Input for manual span gas feed, 6 mm (NpT1/8")
- ⑤ Input for automatic span gas feed, 8 mm (NpT1/4")



#### NOTE

If you lay the heated sample gas line before installing the gas sampling unit - observe the installation of the sample gas line:

- Leave enough length for pulling the gas sampling unit out.

1. Push the cap nut onto the hose.
2. Lead the connection bundle through the installation plate and the cable gland.
3. Connect the 3 tubes:
  - Tecalan tube #1 to V2
  - Tecalan tube #2 to V3
  - PTFE tube 6 mm to V1
4. Push the hoses flush over the hose connections of the hose fitting.
5. Tighten the cap nut by hand.
6. Screw the cable gland tight.

#### 4.4.3.1 Adapter for inch thread (option)

If you want to connect pneumatic lines with inch thread: There is an adapter set with 4 clamping ring screw fittings.

Part No. "Adapter set inch thread": 2083838




Figure 16: Adapter set

#### Installation

1. Wrap the thread with 2 - 2.5 layers of Teflon tape.
2. Tighten the adapter with an open-end wrench until a distinct increase in strength is felt.  
Then tighten by approx. 1/8 to 1/4 turn.

## 4.5 Electrical installation



#### WARNING

Danger to life by electric voltage

- Only allow an authorized electrician to work on the electric system.



#### WARNING

Risk of short-circuit due to condensate.

- Allow the electronics to acclimatize sufficiently before connecting.




Figure 17: Terminal diagram for electrical connections




Figure 18: Terminal diagram for 230 V and 115 V

The electrical connection of the gas sampling unit is made via the connection terminals on the installation plate.

Observe the terminal diagram on the SFU.

The temperature sensors and the heating cartridges are wired ex factory.

- ▶ Remove the protective cover.
- ▶ Perform electrical connections.

## 4.6 Installing the gas sampling tube on the gas sampling unit

### Installing the unheated gas sampling tube




Figure 19: Detailed view of unheated gas sampling tube

- ① Gas sampling tube, unheated
- ② Welding neck flange
- ③ Filter housing flange
- ④ Transition flange
- ⑤ Seal
- ⑥ O-ring
- ⑦ Cable clips
- ⑧ O-ring
- ⑨ Hexagon screw M6x10
- ⑩ Cylinder screw M6x20

1. Lay the insulation hose (red) around the transition flange. Secure with 2 cable clips.
2. Lay the O-ring into the respective groove of the transition flange. Screw the transition flange to the gas sampling unit using the washers, lock washers and M6 cylinder screws.
3. Lay the O-ring into the free groove of the transition flange. Screw the filter housing flange to the transition flange using the washers, lock washers and M6 hexagon screws.
4. Wrap the gas sampling tube connection (1/2" NPT external thread) with Teflon sealing tape. Screw into the corresponding screw connection of the gas sampling unit.

### Installing the heated gas sampling tube

The gas sampling unit with heated gas sampling tube is supplied pre-assembled.

### Installing the pre-filter

The pre-filter can be screwed to the heated and unheated gas sampling tube.

1. Wrap the thread with Teflon tape.
2. Screw the pre-filter onto the tip of the gas sampling tube. Tighten by hand with a wrench.

## 4.7 Installing the SFU on the welding neck flange



### NOTICE

Risk of contamination of the gas sampling unit

Do not install a cold gas sampling unit on the stack.

- ▶ Allow the gas sampling unit to warm up before installing it on the welding neck flange.
- ▶ Warm-up time: Approx. 1.5 h at 25 °C ambient temperature




Figure 20: Installation of gas sampling tube on welding neck flange

- ① Gas sampling tube
- ② Welding neck flange
- ③ Filter housing flange
- ④ Filter housing



### WARNING

Risk of burns on hot surfaces

The gas sampling tube and the gas sampling unit become hot during operation.

- ▶ Wear suitable protective clothing, e.g. heat-resistant gloves.

1. Push the seal over the gas sampling tube.
2. Push the gas sampling unit with probe tube into the welding neck flange.  
The hose outputs of the gas sampling unit have to point downwards.
3. Screw the filter housing flange of the gas sampling unit to the welding neck flange.
4. Fit the weatherproof cover: [see "Weatherproof cover", page 14](#)

## 5 Maintenance

### 5.1 Important Information


**WARNING**

Risk of injury by a heavy load

The device weighs approx. 20 kg.

- ▶ Use proper lifting techniques to lift or move the device.
- ▶ Do not lift the device by holding it at the weatherproof cover. Always hold it at the device base.
- ▶ If necessary, work in pairs.


**WARNING**

Health risk through dangerous sample gas

If dangerous sample gas is applied to the SFU: The operator is responsible for safe handling of sample gas.

- ▶ In addition to these Operating Instructions, observe all local laws, technical rules, and company-internal instructions valid at the site where the SFU is installed.
- ▶ Operate the SFU only in rooms with adequate installation OR install suitable gas monitoring equipment.
- ▶ Channel sample gas off safely.


**WARNING**

Hazard through sample gas pressure

The stacks can have underpressure or overpressure.

- ▶ Observe information from the plant operator.


**WARNING**

Risk of burns on hot surfaces

Filter housing, flanges and sample gas line can be hot.

- ▶ Allow the surface of the device parts to cool down to body temperature or wear suitable protective gloves.


**WARNING**

Danger to life by electric voltage

- ▶ Only allow an authorized electrician to work on the electric system.

### 5.2 Maintenance plan

| No. | Maintenance work                                | Reference                                                  | Interval        |
|-----|-------------------------------------------------|------------------------------------------------------------|-----------------|
| W1  | Replace sintered metal filter element and seals | see "Replacing the sintered metal filter element", page 25 | 3M <sup>1</sup> |
| W2  | Replace glass fiber filter element and seals    | see "Replacing the glass fiber filter element", page 28    | 3M <sup>1</sup> |
| W3  | Check gas connections                           | see "Checking for correct operation", page 34              | 3M <sup>1</sup> |

<sup>1</sup> 3M = every 3 months

| No. | Conversion                                               | Reference                                      | Interval |
|-----|----------------------------------------------------------|------------------------------------------------|----------|
| U1  | Change from sintered metal to glass fiber filter element | see "Retrofitting the filter element", page 31 | -        |

### 5.3 Spare parts

| Required spare parts for W1 and W2                                                                                   | Part number | Quantity required | Picture                                                                             |
|----------------------------------------------------------------------------------------------------------------------|-------------|-------------------|-------------------------------------------------------------------------------------|
| Service kit (contains: 1*2 µm sintered metal filter element, 2*flat seals, 1*O-ring)                                 | 2039002     | 1                 |  |
| Service kit (contains 1*0.1µm glass fiber filter element, 1*flat seal, 1*O-ring)                                     | 2043616     | 1                 |  |
| Required spare parts for U1                                                                                          | Part number | Quantity required | Picture                                                                             |
| Glass fiber filter element with holder (contains 1*0.1µm glass fiber filter element, adapter, 1*flat seal, 1*O-ring) | 2024972     | 1                 |  |



#### NOTE

Further spare parts can be found in the individual System Description provided with the gas sampling unit.

### 5.4 Replacing the sintered metal filter element

You can perform the work while the filter element is hot.

Pay attention to the warning about hot surfaces.

The filter element may be hot inside.



#### WARNING

Risk of burns on hot surfaces

The filter element can reach high temperatures in operation.

- ▶ Wear suitable gloves.
- ▶ Provide a heat-resistant support.



#### WARNING

Hazard by toxic substances

Filter elements can contain toxic substances depending on the sample gas composition.

- ▶ Observe the relevant safety regulations.
- ▶ Dispose of the filter elements in an environmentally compatible manner.


#### Procedure

1. Switch off the fuse of the gas sampling unit in the measuring system.  
The position of the fuse is described in the System Documentation enclosed with the measuring system.
2. Remove the weatherproof cover: [see "Weatherproof cover", page 14.](#)

3. Check all gas connections:
  - Optical condition
  - Tight seat
  - Leak tightness:  
The leak tightness check is performed via the connected measuring system: See the Operating Instructions of the measuring system.

#### Changing the sintered metal filter element

1. Loosen the rotary handle counterclockwise.



- ① Rotary handle
- ② Mounting bracket
- ③ Pressure disk (covered)

2. Swing the mounting bracket to the right.



#### WARNING

Risk of burns on hot surfaces

The inner parts of the gas sampling filter can be especially hot.

- ▶ Wear suitable gloves.
- ▶ Provide a heat-resistant support.




#### CAUTION

Risk of injury due to high weight


- ▶ Do not drop the filter cover.

3. Pull the filter cover out using the rotary handle.
4. If the filter cover is hot: Place the filter cover on a heat-resistant mat.
5. Remove the sintered metal filter element.




- ① Sintered metal filter element
- ② Filter housing

6. Pull out the bottom flat seal with a hook.
7. Insert new bottom flat seal.




- ① Bottom flat seal

8. Replace O-ring and flat seal of the filter cover.



- ① O-ring
- ② Flat seal

9. Insert new or cleaned filter element.  
If one side of the filter element has a groove: The groove must point in the direction of the filter cover.
10. Fit the filter cover.
11. Swing back the mounting bracket. Make sure that the pressure disk is behind the mounting bracket.



- ① Rotary handle
- ② Pressure disk
- ③ Mounting bracket

12. Tighten the rotary handle clockwise.
13. Fit the weatherproof cover again: [see "Weatherproof cover", page 14](#).

## 5.5 Replacing the glass fiber filter element

You can perform the work while the filter element is hot.

Pay attention to the warning about hot surfaces.

The filter can have an internal temperature of 185 °C.



### WARNING

Risk of burns on hot surfaces

The filter element can reach high temperatures in operation.

- ▶ Wear suitable gloves.
- ▶ Provide a heat-resistant support.



### WARNING


Hazard by toxic substances

Filter elements can contain toxic substances depending on the sample gas composition.

- ▶ Observe the relevant safety regulations.
- ▶ Dispose of the filter elements in an environmentally compatible manner.

### Replacing fine filter cartridge

1. Loosen the rotary handle counterclockwise.



- ① Rotary handle
- ② Mounting bracket
- ③ Pressure disk (covered)

2. Swing the mounting bracket to the right.



#### **WARNING**

Risk of burns on hot surfaces

The filter element can reach high temperatures in operation.


- Wear suitable gloves.
- Provide a heat-resistant support.



#### **CAUTION**


Risk of injury due to high weight

- Do not drop the filter cover.




- ① Filter housing
- ② Filter cover
- ③ Mounting bracket
- ④ Pressure disk

3. Pull out the filter cover with glass fiber filter element using the rotary handle.
4. If the filter cover is hot: Place the filter cover on a heat-resistant mat.
5. Pull out the bottom flat seal with a hook.




① Bottom flat seal

6. Loosen the glass fiber filter element from the filter handle by opening the spiral thread.



① O-ring  
② Glass fiber filter element  
③ Rotary handle

7. Insert new bottom flat seal.
8. Renew the O-ring in the filter cover.
9. Fit new or cleaned glass fiber filter element on the filter cover. Tighten the spiral thread.  
If one side of the filter element has a groove: The groove must point in the direction of the filter cover.
10. Replace the filter cover.



① Rotary handle  
② Pressure disk  
③ Mounting bracket

11. Swing back the mounting bracket. Make sure that the pressure disk is behind the mounting bracket.
12. Tighten the rotary handle clockwise.
13. Fit the weatherproof cover again: [see "Weatherproof cover", page 14.](#)

## 5.6 Retrofitting the filter element

You can perform the work while the filter element is hot.

Pay attention to the warning about hot surfaces.

The filter can have an internal temperature of 185 °C.



### WARNING

Risk of burns on hot surfaces

The filter element can reach high temperatures in operation.

- ▶ Wear suitable gloves.
- ▶ Provide a heat-resistant support.



### WARNING

Hazard by toxic substances

Filter elements can contain toxic substances depending on the sample gas composition.


- ▶ Observe the relevant safety regulations.
- ▶ Dispose of the filter elements in an environmentally compatible manner.

### Procedure

1. Switch off the fuse of the gas sampling unit in the measuring system.  
The position of the fuse is described in the System Documentation enclosed with the measuring system.
2. Remove the weatherproof cover: [see "Weatherproof cover", page 14.](#)
3. Check all gas connections:
  - Optical condition
  - Tight seat
  - Leak tightness:  
The leak tightness check is performed via the connected measuring system: See the Operating Instructions of the measuring system.

### Retrofitting the sintered metal filter element to a glass fiber filter element

1. Loosen the rotary handle counterclockwise.



- ① Rotary handle
- ② Mounting bracket
- ③ Pressure disk (covered)

2. Swing the mounting bracket to the right.

**WARNING**

Risk of burns on hot surfaces

The filter element can reach high temperatures in operation.


- ▶ Wear suitable gloves.
- ▶ Provide a heat-resistant support.

**CAUTION**

Risk of injury due to high weight


- ▶ Do not drop the filter cover.

3. Pull the filter cover out using the rotary handle.
4. If the filter cover is hot: Place the filter cover on a heat-resistant mat.
5. Remove the sintered metal filter element.




- ① Sintered metal filter element  
② Filter housing

6. Pull out the bottom flat seal with a hook.
7. Insert new bottom flat seal.




- ① Bottom flat seal

8. Replace O-ring and flat seal of the filter cover.




- ① O-ring
- ② Position of flat seal

9. Fit the glass fiber filter element on the filter cover. Tighten with the spiral thread. If one side of the glass fiber filter element has a groove: The groove must point in the direction of the filter cover.



- ① O-ring
- ② Glass fiber filter element
- ③ Rotary handle

10. Replace the filter cover.
11. Swing back the mounting bracket. Make sure that the pressure disk is behind the mounting bracket.



- ① Rotary handle
- ② Pressure disk
- ③ Mounting bracket

12. Tighten the rotary handle clockwise.
13. Fit the weatherproof cover again: [see "Weatherproof cover", page 14](#)

## 5.7 Checking for correct operation

- Check all fastening screws of the housing for tight seat.
- Check the sample gas line for damage.
- Check all hose fittings for tight seat.
- Check gas sampling unit for cleanness, dryness and freedom from corrosion.
- Check all electric connections for freedom from corrosion and tight seat.
- Check grounding conductors are free from corrosion.
- Perform a leak tightness check:  
The leak tightness check is performed via the connected measuring system: See the Operating Instructions of the measuring system.

## 6 Troubleshooting

### 6.1 Troubleshooting

| Fault                              | Possible cause                                    | Correction                                           |
|------------------------------------|---------------------------------------------------|------------------------------------------------------|
| Gas throughput decreases           | Pre-filter contaminated                           | Clean or replace                                     |
|                                    | Filter element contaminated                       |                                                      |
| Heating failed                     | Heating cartridge or temperature sensor defective | If necessary, replace seal or defective component    |
|                                    | Defective seal                                    | Replace seal                                         |
| Contaminated or corroded gas paths | Defective or missing pre-filter                   | Replace                                              |
| Leaky non-return valves            | Contaminated instrument air                       | Replace<br>Check the purity of the instrument air    |
| Leaky main valve                   | Valve seating contaminated or damaged             | Replace the valve cone<br>Replace the filter housing |
|                                    | Metal bellow leaky                                | Replace the metal bellow                             |

## 7 Disposal

The device can easily be disassembled into its components which can then be sent to the respective raw material recycling facilities.

**WARNING**

Filters and lines with sample gas contact can contain toxic substances.

Observe the relevant safety regulations.

- Depending on their components, filters and lines with sample gas contact must be disposed of according to the legal regulations. If required, they must be treated as hazardous waste.
-

## 8 Technical data

### 8.1 Compliances and Standards

#### Compliance

The technical design of the devices SFU-BF NI, SFU-BF NI GL and SFU-3V NI correspond to the following guidelines and standards:

- EC Directive: LVD (Low Voltage Directive)  
EN 61010-1: Safety requirements for electrical equipment for measurement, control and laboratory use

Further standards: See Declaration of Conformity provided with the device

#### Additional standards for SFU-BF NI GL

- MARPOL Annex VI and NTC 2008 - MEPC.177(58)
- Guidelines for exhaust gas cleaning systems - MEPC.184(59)
- DNV GL Rules for Classification and Construction, Part VI Additional Rules and Guidelines Chapter 7, Guidelines for the Performance of Type Approvals, Test Requirements for Electrical / Electronic Equipment and Systems (2012)

### 8.2 Dimensions




Figure 21: SFU-BF NI and SFU-BF NI GL




Figure 22: SFU-BF NI and SFU-BF NI GL




Figure 23: SFU-3V NI




Figure 24: SFU-3V NI

### 8.3 Operating data

| Ambient conditions                                                                                                                                                                     | SFU-BF NI                                                                                                                                                                                                                           | SFU-BF NI GL                                                                                                                   | SFU-3V NI                                                                                                               |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|
| Ambient temperature                                                                                                                                                                    | +5 ... +45 °C (+40 ... 110 °F)                                                                                                                                                                                                      |                                                                                                                                |                                                                                                                         |
| Storage temperature                                                                                                                                                                    | -20 ... +60 °C (-5 ... 140 °F)                                                                                                                                                                                                      |                                                                                                                                |                                                                                                                         |
| Relative humidity                                                                                                                                                                      | Max. 80%                                                                                                                                                                                                                            |                                                                                                                                |                                                                                                                         |
| Degree of protection                                                                                                                                                                   | IP23                                                                                                                                                                                                                                | IP23                                                                                                                           | IP23                                                                                                                    |
| Installation                                                                                                                                                                           | SFU-BF NI                                                                                                                                                                                                                           | SFU-BF NI GL                                                                                                                   | SFU-3V NI                                                                                                               |
| Tubing SFU-BF NI and SFU-BF NI GL <ul style="list-style-type: none"> <li>• Main valve</li> <li>• Zero gas</li> <li>• Backflush</li> <li>• Sample gas line</li> </ul>                   | .<br>.<br>Dimensions: <ul style="list-style-type: none"> <li>• 8 mm</li> <li>• 6 mm</li> <li>• 8 mm</li> <li>• 6 mm</li> </ul>                                                                                                      | .<br>.<br>Dimensions: <ul style="list-style-type: none"> <li>• 8 mm</li> <li>• 6 mm</li> <li>• 8 mm</li> <li>• 6 mm</li> </ul> | ---                                                                                                                     |
| Tubing SFU20-Hg <ul style="list-style-type: none"> <li>• Control valves</li> <li>• Span gas manual</li> <li>• Span gas automatic</li> <li>• Sample gas line</li> </ul>                 | ---                                                                                                                                                                                                                                 | ---                                                                                                                            | Dimensions: <ul style="list-style-type: none"> <li>• 6 mm</li> <li>• 6 mm</li> <li>• NpT1/4"</li> <li>• 6 mm</li> </ul> |
| Compressed air <ul style="list-style-type: none"> <li>• Main valve</li> <li>• Zero gas</li> <li>• Backflush</li> </ul>                                                                 | Pressure: <ul style="list-style-type: none"> <li>• 5 - 6 bar (500 - 600 kPascal)</li> <li>• 2.5 - 3 bar (250 - 300 kPascal)</li> <li>• 5 - 6 bar (500 - 600 kPascal)</li> </ul>                                                     |                                                                                                                                | ---                                                                                                                     |
| Flange<br>NW = Rated width<br>ND = Rated pressure                                                                                                                                      | NW 50, ND 16<br>NW 65, ND 6 or 16<br>NW 80, ND 16<br>NW 100, ND 16<br>ANSI 4"                                                                                                                                                       | NW 65, ND 6                                                                                                                    | NW 50, ND 16<br>NW 65, ND 6 or 16<br>NW 80, ND 16<br>ANSI 4"                                                            |
| Fitting position                                                                                                                                                                       | Horizontally with an inclination of approx. 10° ( <a href="#">see "Installing the welding neck flange", page 15</a> )                                                                                                               |                                                                                                                                |                                                                                                                         |
| Power consumption                                                                                                                                                                      | SFU-BF NI                                                                                                                                                                                                                           | SFU-BF NI GL                                                                                                                   | SFU-3V NI                                                                                                               |
| Probe filter                                                                                                                                                                           | Max. 115/230 V, 50-60 Hz, 450 VA                                                                                                                                                                                                    |                                                                                                                                |                                                                                                                         |
| Heated gas sampling tube                                                                                                                                                               | Max. 115/230 V, 50-60 Hz, 450 VA (0.8, 1, 1.5, 2 m)                                                                                                                                                                                 |                                                                                                                                |                                                                                                                         |
| Device characteristics                                                                                                                                                                 | SFU-BF NI                                                                                                                                                                                                                           | SFU-BF NI GL                                                                                                                   | SFU-3V NI                                                                                                               |
| Materials <ul style="list-style-type: none"> <li>• Gas sampling tube</li> <li>• Enclosure</li> <li>• Parts attached to enclosure</li> <li>• Screw fittings</li> <li>• Seals</li> </ul> | Materials <ul style="list-style-type: none"> <li>• Application-dependent</li> <li>• Aluminum, coated</li> <li>• High grade steel 1.4541 resp. 1.4301</li> <li>• High grade steel ANSI 316 (V4A)</li> <li>• PTFE/FKM/FFKM</li> </ul> |                                                                                                                                |                                                                                                                         |
| Weight                                                                                                                                                                                 | Approx.. 20 kg (without flange and probe tube)                                                                                                                                                                                      |                                                                                                                                |                                                                                                                         |
| Gas temperature in filter<br>Heating temperature<br>Gas temperature in stack                                                                                                           | Max. 250 °C<br>Max. 200 °C<br>Unheated probe tube: Max. 1300 °C<br>Heated probe tube: Max. 200 °C                                                                                                                                   |                                                                                                                                |                                                                                                                         |
| Temperature control                                                                                                                                                                    | External, Pt100                                                                                                                                                                                                                     |                                                                                                                                |                                                                                                                         |
| Limit monitoring                                                                                                                                                                       | External heating controller                                                                                                                                                                                                         |                                                                                                                                |                                                                                                                         |
| Purge gas flow                                                                                                                                                                         | Approx. 12 l/min                                                                                                                                                                                                                    |                                                                                                                                |                                                                                                                         |
| Backpurge gas flow                                                                                                                                                                     | Approx. 80 l/min                                                                                                                                                                                                                    |                                                                                                                                |                                                                                                                         |
| Sample gas throughput                                                                                                                                                                  | 300 ... 1000 l/h                                                                                                                                                                                                                    |                                                                                                                                |                                                                                                                         |

| Device characteristics                               |     |     |      | SFU-BF NI                                       | SFU-BF NI GL | SFU-3V NI |      |
|------------------------------------------------------|-----|-----|------|-------------------------------------------------|--------------|-----------|------|
| Heating up time                                      |     |     |      | Approx. 1,5 h (from room temperature to 200 °C) |              |           |      |
| Standard lengths of unheated gas sampling tubes [mm] |     |     |      |                                                 |              |           |      |
| SFU-BF NI                                            | 200 | 500 | 800  | 1000                                            | 1200         | 1500      | 2000 |
| Standard lengths of heated gas sampling tubes [mm]   |     |     |      |                                                 |              |           |      |
| SFU-BF NI                                            | 500 | 800 | 1000 | 1500                                            | 2000         |           |      |
| SFU-3V NI                                            | 500 | 800 | 1000 | 1500                                            | 2000         |           |      |
| SFU-BF NI GL                                         | 500 | 800 | ---  | ---                                             | ---          |           |      |

8029819/YJ80/V3-0/2015-08

[www.addresses.endress.com](http://www.addresses.endress.com)

---

For more Endress+Hauser product please visit: [www.ainstru.com](http://www.ainstru.com)  
Mail: [Sales@ainstru.com](mailto:Sales@ainstru.com)